

LEWIS AND CLARK COUNTY FUELING AND MG/CL SYSTEMS

ADDITIONAL QUESTION FROM INTERESTED PARTY

Date of Responses: December 5, 2024
Date Bids are Due: December 11, 2024
Time Bids are Due: 4:00 pm
Location of Bid Submittal: Lewis and Clark County Commissioner's Office
316 N. Park Ave., Room 345
Helena, MT 59623

TO ALL INTERESTED PARTIES:



This document summarizes the questions from interested parties and the responses to each question.

PROJECT QUESTIONS:

- Q1:** Can Great West Provide a detail for the steel catch basin to include some sizing, steel gauge requirements, PVC connection details, ect?
- A1:** Attached is a catch basin detail from one possible manufacturer. The catch basin shall be constructed of 12 gauge steel.

Questions From:

Josh Leiva
Helena Sand & Gravel
406-442-1185



Grate Detail

NOTE:
1/2" HD Diamond Plate Grate

This drawing is the property of Riverside Steel and may not be distributed or reproduced without the express written permission of Riverside Steel, Inc.

ITEM NO. : SS2424T5H

RIVERSIDE STEEL, INC. 3102 WARREN-SHARON RD. VIENNA, OHIO 44473	DRAWING: 24" Square Catch Basin 9" Deep
DRAWN BY: SJM	SCALE: None
CHK BY: JM	DATE: 12/3/24
MAT'L: 12 Ga. Carbon Steel	CUSTOMER: